# **S QuadraTherm<sup>®</sup>640i/780i** QUICK START GUIDE

This Quick Start Guide for the QuadraTherm<sup>®</sup> 640i/780i Thermal Mass Flow Meter gives easy set up and installation instructions. For complete simplified instructions, please download the QuadraTherm Instuction manuel.

#### **IMPORTANT!** Before installing meter, follow the steps below

#### 🛃 Step 1. Download Instruction Manual

To get technical information, download to the QuadraTherm 640i/780i Instruction Manual and the Smart Interface Portal (SIP) Software Manual at sierrainstruments.com/guadratherm-manual

Step 2. Download FREE Software - Get Apps Download the most current Smart Interface Portal (SIP) product software at sierrainstruments.com/640i-780i-SIP Use the included 9-pin, RS-232 cable with fly leads to connect the meter to your computer

**Important.** If you do not have an internet connection, you must download the software to a USB stick or other storage device.

#### Safety

1. Apply power only after reviewing the wiring diagrams in the "Installation and Wiring" section below or in Chapter 2 of the Instruction Manual. Apply gas flow only after checking plumbing connections for leaks.

#### Installation and Wiring

- 1. Install the meter in the pipe. Make sure you have enough straight run pipe for your installation. See Figure 2-1 in Chapter 2 of the Instruction Manual for the straight run requirements.
- 2. Connect AC or DC power per the meter configuration received. See the diagrams below or Figures 2-5, 2-6, and 2-7 in Chapter 2 in the Instruction Manual for more information.



- 3. After a short start-up routine, the meter will begin displaying measured variables using the setup as supplied to the factory from your application data sheet. You will access this data via the display (if ordered) or the Smart Interface Program (SIP) if connected and installed on your computer. The meter will scroll through three screens: flow and temperature, pressure (if ordered), and totalizer. See Chapter 3: Operating & Programming in your Instruction Manual.
- 4. Connect the analog outputs (if you are going to use them). The meter comes with three non-isolated outputs for flow, temperature, and pressure.

# Using The Push Buttons and Display

- 1. In general terms, the display menu system consists of a Main Menu, the Set-Up Menu, and a Sub-Menu used to program each item in the Set-Up Menu. There is also a series of data entry or pull-down screens to enter your set-up data for each parameter. Menus may be adjusted using the six buttons on the front of the unit: up ▲, down ♥, left ▲, right ▶, enter ➡, and escape/cancel ⊗.
- 2. If you're updating a value, and that value is currently set to "0", pressing the up key will increase the value to "1" while pressing the left button will move the menu selection to the left or the data entry field to the left if updating a menu value. Pressing the enter key accepts the current value.
- 3. While editing information, the screen data "flashes" to show that you are actively editing. Pressing the enter 🖬 key after you are done editing will permanently write the data to the meter's memory while pressing the escape/cancel 🐼 key returns to the last previous menu value. For more detailed information about operating your push button display, see Chapter 3: Operating & Programming in your Instruction Manual.

### Changing Application Information In The Field Using qTherm Dial-A-Gas® & Dial-A-Pipe®

The meter comes programmed from the factory with your application information, but it is easy to change this information using Sierra's unique qTherm Dial-A-Gas® and Dial-A-Pipe<sup>™</sup> feature. You can access both features using either the push buttons on the display or an RS-232 connection between your computer and the meter using the provided Smart Interface Program (SIP) Software.

# Using Your Display to Change Gas and Pipe Size: qTherm Dial-A-Gas & Dial-A-Pipe



Watch the qMix overview video to learn about activation and how to use qMix. www.sierrainstruments.com/qmix-tutorial

- To access this Dial-A-Gas and Dial-A-Pipe information in the Sub-Menu of the display, enter the meter's password. From the scrolling menu, press the enter key, and you will be asked for a password. Enter 0000 for the password (it is already there by default and can be changed later); then press the enter key. You will arrive at the Calibration Sub-Menu. From here, press the enter key. See menu navigation diagram below or in Chapter 3 the Instruction Manual for more information.
- 2. qTherm Dial-A-Gas: Change Gas

To change and select your gas, the display will show "Dial-A-Gas" with the principal gas listed from your application datasheet (ADS), hit the enter  $\leftarrow$  key, and it will begin to flash; use the  $\frown$  buttons to scroll through the other gases. Hit enter  $\leftarrow$  to select another gas. See sub-menu diagram below or Chapter 3 in the Instruction Manual for more information about using the Dial-A-Gas feature.

3. qTherm Dial-A-Pipe: Change Pipe Size

Go to the Dial-A-Pipe menu to set the internal diameter (ID). Hit enter () to enter a new pipe ID using the buttons to enter the desired value, and the enter key () to save the value. Use a similar process to enter the pipe type (ex: stainless steel-smooth) and to select your engineering units. See table below or Chapter 3 in the Instruction Manual for more information.



#### Menu Navigation Diagram

# Using RS-232 & Smart Interface Program (SIP) Software to Change Gas and Pipe Size: Dial-A-Gas & Dial-A-Pipe

1. First, install the RS-232 cable (provided) using the diagram below.



- 2. Next, install the SIP program (see p. 61 in Instruction Manual):
  - Click on the file (640i & 780i Smart Interface Program). This file is self-extracting.
  - Follow instructions for installing the files.
  - The process takes 5 to 10 minutes total, depending on speed of your computer.
- 3. Run the program (note meter must be powered on to run the SIP program). The main home page interface (see Figure: 1 below).
- 4. From the home page, select the appropriate Com Port, and the SIP will read the meter's parameters as defined by your application datasheet. SeeFigure 1.
- 5. qTherm Dial-A-Gas & Units

To change your gas and units, select the Dial-A-Gas & Units button on the home page under the meter control section. Use the pull down menus on the Dial-A-Gas screen (Figure: 2 below) to select your gas and units. Select Save and Exit to return to the main menu screen. See Appendex B in the Instruction Manual.



#### 6. gTherm Dial-A-Pipe

To change your pipe properties select the Dial-A-Pipe button on the home screen (Figure: 1). Use the pull down menus in the qTherm Dial-A-Pipe screen (Figure: 3 below) to select your pipe properties. Select Save and Exit to return to the home screen. Appendex B in the Instruction Manual.

7. Your meter set-up is now complete. Your updated meter parameters can be viewed from the SIP main screen.

Figure: 3



# **Contact Us**

Email Technical Support: service@sierrainstruments.com • 24 Hour Live Help Online: www.sierrainstruments.com/livehelp

- Telephone Technical Support–North America: 800.866.0200 or 831.373.0200 Europe, Middle East, Africa + 3172 5071 400 • Asia: + 8620 3435 4870